## Notice of Exceedance of Groundwater Protection Standards Winyah Generating Station, Ash Pond A

The South Carolina Public Service Authority (Santee Cooper) is implementing the April 17, 2015 U.S. Environmental Protection Agency (U.S. EPA) Federal Coal Combustion Residuals (CCR) Rule (40 CFR § 257 and 261) for the Winyah Generating Station, located in Georgetown County, South Carolina.

In accordance with 40 CFR §257.95(g), Arsenic and Lithium, Appendix IV constituents, exceeded the groundwater protection standard for one of the wells at Ash Pond A.

Per the 2019 Semi-Annual Groundwater Assessment Monitoring Data Statistical Evaluation (January 30, 2020), an additional Appendix IV constituent, Molybdenum, exceeded the groundwater protection standard for one or more of the wells at Ash Pond A. Therefore, it has been added to the list of SSLs.

Since Molybdenum has already been identified as an SSL for Ash Pond B, the joint CMA for both Ash Pond A & B does not need to be revised.