

Jeremy Poetzsch

From: Mikki Crocker
Sent: Monday, November 18, 2024 11:22 AM
To: Jeremy Poetzsch
Subject: 2024 CGS Landfill Inspection Report Update
Attachments: IMG_5700.JPG; IMG_5699.JPG; IMG_5698.JPG

Jeremy,

As you are aware, the 2024 Coal Combustion Residual Class 2 and Class 3 Landfill Inspection Report for Cross Generating Station identified an area on the south side of the class 2 landfill experiencing minor seepage at the toe of the slope. Repairs have been completed addressing the seepage on the slope and the area has been seeded for stabilization. Please let Civil Projects & Dam Safety know if you have any questions or need additional information regarding the repair.

Thank you,

Mikki Crocker, PE

📍 Civil Projects (OC-08), 1 Riverwood Drive, Moncks Corner, SC 29461

☎ 843.761.8000 x 4745

📧 mikki.crocker@santecooper.com

